

MINIMUM 15# FELT PAPER

PRE-ENGINEERED TRUSSES  
AT 24" ON CENTER

MIN. 7/16" ROOF SHEATHING  
WITH PLYWOOD CLIPS

CARRIAGE BOLTS  
SIZED PER LOADS

(2) 2X  
TYPICAL BEAM

BRACING PER TRUSS  
MANUFACTURERS  
SPECIFICATIONS

12'-0" MAXIMUM SIDE WALL HEIGHT

EXTERIOR WALL  
COVERING

2X PURLINS 24" ON CENTER  
MAXIMUM

4X6 MIN. TREATED WALL POSTS  
6X6 MIN. TREATED CORNER POSTS  
SEE PLAN FOR SPACING


3-1/2" THICK CONCRETE SLAB ON  
GRADE ( 3,500 PSI CONCRETE WITH  
AIR) OVER VAPOR BARRIER AND 4"  
GRAVEL BASE

48" MINIMUM

BACK FILL (CEMENT, DIRT, GRAVEL)

POST FOOTING DEPTH  
SHALL BE HALF THE  
DIAMETER OF POST  
FOOTING

POST FOOTING DIAMETER  
SIZED AS REQUIRED FOR  
LOADING



# TYPICAL POLE BARN

## WALL SECTION

SCALE: 3/4" = 1'-0"